

Cameras link : [View Camera](#)Cameras Details : **Browser: Internet Explorer URL: http://103.59.196.38:8084/ Username: bplkb Password: 123456**

Sr.No	Field	Status of Compliance	Compliance	Attachment	Mandatory / Desired	Score	Marks Assign by officer
1	2	3	4	5	6	7	
1	Whether PM2.5& PM10.0 sensors installed at project site?	Yes	Air sensor installed and link connected	View File	Mandatory	15	-
2	Whether continuous dust/wind breaking walls, tarpaulin or green-net, wind-fencing or scaffolding sheet of appropriate height have been provided around the periphery of the construction site and also tarpaulin or green-net on scaffolding around the area under-construction and the building?	Yes	Green Net is used as wind breaking walls. Also site is covered with GI Sheets around the boundary of site.	View File	Mandatory	15	-
3	Whether building material is covered during transportation?	Yes	The raw material is brought duly covered.	View File	Mandatory	15	-
4	Whether wind fences/screens and/or enclosures/coverings for storage piles being utilized? No loose soil or sand or construction & Demolition Waste or any other construction material that causes dust shall be left uncovered.	Yes	Raw Material and construction waste is always covered and water sprinkling is done from time to time. Also barricading is done as wind breaker.	View File	Mandatory	15	-
5	Whether no grinding and cutting of building materials in open area and wet-jet is being used ?	Yes	Cutting and grinding work is done in closed area and wet jet is being used always.	View File	Mandatory	15	-
6	Whether unpaved surfaces and areas with loose soil are adequately sprinkled with water to suppress dust? Ideally site to be fitted with fine water spraying nozzle system?	Yes	Water sprinkling is done on the unpaved areas regularly.	View File	Mandatory	15	-
7	Whether all vehicles including carrying construction material and construction debris of any kind cleaned and wheels / under body washed before leaving the construction site?	Yes	Wheel washer is made at entry/exit gate so that every vehicle coming or leaving the site should pass through the same.	View File	Mandatory	15	-
8	Whether DG set installed (with acoustic enclosure & stack height)?	Yes	DG sets are installed with adequate stack height.	View File	Mandatory	15	-
9	Whether video-fencing with remote connectivity installed at project site?	Yes	Camera has been installed and link has been shared.	View File	Mandatory	15	-

Sr.No	Field	Status of Compliance	Compliance	Attachment	Mandatory / Desired	Score	Marks Assign by officer
1	2	3	4	5	6	7	
10	Whether proper collection, segregation, disposal& recycling of C&D Waste is ensured and due log book of the same is maintained?	Yes	Construction waste is collected at site and used later to fill the space	View File	Mandatory	10	-
11	Whether mixing processes is carried out in enclosures?	Yes	Mixing process is carried out in enclosures.	View File	Mandatory	10	-
12	Whether steps have been taken to ensure that debris/ construction material is not dumped in public roads/ undesignated sites?	Yes	All material is stored within the site.	View File	Mandatory	10	-
13	Whether dust mitigation measures be displayed prominently at the construction site for easy public viewing?	Yes	Boards with dust mitigation measures have been displayed at different locations at site.	View File	Mandatory	10	-
14	Whether roads leading to or at construction sites are paved and blacktopped i.e., metallic roads?	Yes	Roads leading to construction sites are paved.	View File	Mandatory	10	-
15	Whether options employed for C&D waste recycling?	Yes	Construction waste is segregated and stored to use later for filling.		Desired	5	-
16	Whether every worker working on the construction site and involved in loading, unloading and carriage of construction material and construction debris are provided with dust-mask to prevent inhalation of dust particles?	Yes	Dust masks are provided to every worker working at site.	View File	Desired	5	-
17	Whether arrangement provided for medical help, investigation and treatment to workers involved in the construction of building and carry of construction material and debris relatable to dust emission?	Yes	Medical facility is provided at site.	View File	Desired	5	-
18	Whether material drop height is minimized at the transfer point and enclosure around transfer point provided?	Yes	Shutes have been provided for dropping the construction waste.	View File	Desired	5	-
19	Whether designing layout of the construction site to minimize fugitive dust generation potential, including access roads, entrances and exits, storage piles, vehicle staging areas, and other potential sources of dust emissions.	Yes	Movement of vehicle within the site is as per the plan attached.	View File	Desired	5	-
20	Whether pre-fabricated materials and modular construction units are being used?	No	No pre-fabricated material or modular construction units are used.		Desired	0	-
21	Whether proper shape storage piles provided so that they do not have steep sides or faces?	Yes	Material is stored avoiding the steep side or faces.	View File	Desired	5	-

Sr.No	Field	Status of Compliance	Compliance	Attachment	Mandatory / Desired	Score	Marks Assign by officer
1	2	3	4	5	6	7	
22	Whether stabilized earthworks with stone / soil / geotextiles / Vegetation / compacting?	No	Earthwork is stabilized with compacting the sand by water sprinkling		Desired	0	-
23	Whether Anti-Smog Gun(s) has been installed at the construction site? (For construction area 5000-10000Sqm 1 smog gun , 10000-15000Sqm 2 smog guns, 15000-20000Sqm 3 smog guns and for more than 20000Sqm 4 smog guns are to be installed as per CAQM directions)	Yes	Anit Smog Guns has been installed at site.	View File	Desired	5	-
24	Whether treated water is used to mitigate dust & wet process for Sand and grit blasting and facade cleaning generation on construction site?	Yes	STP treated water is purchased from DJB Rithala and used.	View File	Desired	5	-
25	Whether dust suppressants are being used?	Yes	Water sprinkling is done on regular intervals.		Desired	5	-
26	Whether distances travelled for delivery of materials minimized?	Yes	Raw material is purchased in bulk and stored at our site only.		Desired	5	-
27	Whether vehicles used for transport of materials have valid PUC certificate?	Yes	No vehicle is permitted within the site without valid PUC	View File	Desired	5	-