

Cameras link : [View Camera](#)

Cameras Details : Browser: Internet Explorer URL: http://103.59.196.38:8084/ Username: bplkb Password: 123456

Sr.No	Field	Status of Compliance	Compliance	Attachment	Mandatory / Desired	Score	Marks Assign by officer
1	2	3	4	5	6	7	
1	Whether PM2.5& PM10.0 sensors installed at project site?	Yes	Air sensor in installed and connected.	<a href="#">View File</a>	Mandatory	15	-
2	Whether continuous dust/wind breaking walls, tarpaulin or green-net, wind-fencing or scaffolding sheet of appropriate height have been provided around the periphery of the construction site and also tarpaulin or green-net on scaffolding around the area under-construction and the building?	Yes	GI sheets have been installed around the boundary of the site and green net is put on where ever necessary.	<a href="#">View File</a>	Mandatory	15	-
3	Whether building material is covered during transportation?	Yes	Building Material is brought duly covered.	<a href="#">View File</a>	Mandatory	15	-
4	Whether Anti-Smog Gun(s) has been installed at the construction site?	Yes	Anti Smog Gun is used for water sprinkling at regular intervals.	<a href="#">View File</a>	Mandatory	15	-
5	Whether wind fences/screens and/or enclosures/coverings for storage piles being utilized? No loose soil or sand or construction & Demolition Waste or any other construction material that causes dust shall be left uncovered.	Yes	Raw material and construction waste is stored separately duly covered. Water sprinkling is done to avoid dust emission.	<a href="#">View File</a>	Mandatory	15	-
6	Whether no grinding and cutting of building materials in open area and wet-jet is being used ?	Yes	Grinding and cutting of the building material is done in covered area.	<a href="#">View File</a>	Mandatory	15	-
7	Whether unpaved surfaces and areas with loose soil are adequately sprinkled with water to suppress dust? Ideally site to be fitted with fine water spraying nozzle system?	Yes	Water sprinkling is done on the un-paved surfaces with regular intervals.	<a href="#">View File</a>	Mandatory	15	-
8	Whether all vehicles including carrying construction material and construction debris of any kind cleaned and wheels / under body washed before leaving the construction site?	Yes	Wheel washer is made at the entry/exit gate from where the vehicles have to pass through.	<a href="#">View File</a>	Mandatory	15	-
9	Whether DG set installed (with acoustic enclosure & stack height)?	Yes	DG Set installed at site is with acoustic enclosure and with adequate stack height.	<a href="#">View File</a>	Mandatory	15	-

Sr.No	Field	Status of Compliance	Compliance	Attachment	Mandatory / Desired	Score	Marks Assign by officer
1	2	3	4	5	6	7	
10	Whether video-fencing with remote connectivity installed at project site?	Yes	Camera has been installed and link provided.	<a href="#">View File</a>	Mandatory	15	-
11	Whether proper collection, segregation, disposal& recycling of C&D Waste is ensured and due log book of the same is maintained?	Yes	Construction waste is segregated and stored separately for reusing the same for filling the gaps.	<a href="#">View File</a>	Mandatory	10	-
12	Whether mixing processes is carried out in enclosures?	Yes	Mixing is done in the covered areas and water sprinkling is done at scheduled times to keep the raw material wet.	<a href="#">View File</a>	Mandatory	10	-
13	Whether steps have been taken to ensure that debris/ construction material is not dumped in public roads/ undesignated sites?	Yes	All the raw material and construction waste is stored within the site.	<a href="#">View File</a>	Mandatory	10	-
14	Whether dust mitigation measures be displayed prominently at the construction site for easy public viewing?	Yes	Boards mentioning the dust mitigation measures are placed at different locations at site.	<a href="#">View File</a>	Mandatory	10	-
15	Whether roads leading to or at construction sites are paved and blacktopped i.e., metallic roads?	Yes	Roads leading to construction site are paved and black topped.	<a href="#">View File</a>	Mandatory	10	-
16	Whether options employed for C&D waste recycling?	Yes	Construction waste is segregated and stored separately to use later for back filling.	<a href="#">View File</a>	Desired	5	-
17	Whether every worker working on the construction site and involved in loading, unloading and carriage of construction material and construction debris are provided with dust-mask to prevent inhalation of dust particles?	Yes	Every worker is provided with dust mask and other safety gears.	<a href="#">View File</a>	Desired	5	-
18	Whether arrangement provided for medical help, investigation and treatment to workers involved in the construction of building and carry of construction material and debris relating to dust emission?	Yes	First Aid facility has been provided and also doctor visits at regular intervals.	<a href="#">View File</a>	Desired	5	-
19	Whether material drop height is minimized at the transfer point and enclosure around transfer point provided?	Yes	For dropping the construction waste from height shutes have been provided.	<a href="#">View File</a>	Desired	5	-

Sr.No	Field	Status of Compliance	Compliance	Attachment	Mandatory / Desired	Score	Marks Assign by officer
1	2	3	4	5	6	7	
20	Whether designing layout of the construction site to minimize fugitive dust generation potential, including access roads, entrances and exits, storage piles, vehicle staging areas, and other potential sources of dust emissions.	Yes	Vehicle movement has been planned to avoid dust emission.	<a href="#">View File</a>	Desired	5	-
21	Whether pre-fabricated materials and modular construction units are being used?	No	No pre-fabricated material is used.		Desired	0	-
22	Whether proper shape storage piles provided so that they do not have steep sides or faces?	Yes	Steep sides are avoided during the storage of construction material.	<a href="#">View File</a>	Desired	5	-
23	Whether stabilized earthworks with stone / soil / geotextiles / Vegetation / compacting?	Yes	Earthwork is stabilized with compacting the sand by water sprinkling.	<a href="#">View File</a>	Desired	5	-
24	Whether treated water is used to mitigate dust & wet process for Sand and grit blasting and facade cleaning generation on construction site?	Yes	STP Treated Water is purchased from DJB Rithala plant for sprinkling the water.	<a href="#">View File</a>	Desired	5	-
25	Whether dust suppressants are being used?	Yes	Water sprinkling is done for suppression of dust.	<a href="#">View File</a>	Desired	5	-
26	Whether distances travelled for delivery of materials minimized?	Yes	Purchase of raw material is planned and order for raw material is placed in bulk.		Desired	5	-
27	Whether vehicles used for transport of materials have valid PUC certificate?	Yes	Vehicles having valid PUC are used for transport of materials.	<a href="#">View File</a>	Desired	5	-